

VT Industries, Inc.
890 Central Court
New Albany, Indiana 47150
Toll Free (800) 626-6271
Fax (712) 368-4111
Website www.vtindustries.com
E-mail door_info@vtindustries.com

May 2010

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all “Specifier Notes” when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08212 (08 14 16)

FLUSH WOOD VENEER DOORS

Specifier Notes: This section covers VT Industries Artistry Collection flush wood veneer doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Interior Flush Wood Veneer Doors.

Specifier Notes: Edit the following list as required.

1. Five-ply flush bonded doors.
2. Flush fire-rated wood doors.
3. Lead-lined doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.
- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.
- D. Section 08800 (08 80 00) – Glazing.
- E. Section 10225 (08 91 26) – Door Louvers.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. ANSI A208.1 – Particleboard.
- B. AWI/AWMAC/WI Architectural Woodwork Standards, Section 5 – Finishing.
- C. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 – Doors.
- D. NFPA 80 – Standard for Fire Doors and Other Opening Protectives.
- E. UBC 7-2-1997/UL 10C – Positive Pressure Fire Tests of Door Assemblies.
- F. WDMA I.S.1-A – Architectural Wood Flush Doors.
- G. WDMA I.S. 10 – Industry Standard for Testing Cellulosic Composite Materials for Use in Fenestration Products.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data, including door construction description and WDMA I.S.1-A and AWS classifications.
- C. Schedules: Submit manufacturer's schedules, including door dimensions, cutouts, species, finish, and hardware. Reference individual door numbers as indicated on the Drawings.
- D. Samples: Submit manufacturer's door finish samples, showing range of color variation.

Specifier Notes: Include the following paragraph when specifying sound-retardant doors.

- E. Test Reports: Submit manufacturer's test results of STC ratings from testing performed by independent testing agency for sound-retardant doors.
- F. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- G. Environmental Documentation: Submit manufacturer's environmental documentation for the following LEED credits.
 - 1. MR Credit 4: Recycled Content.
 - 2. MR Credit 5: Regional Materials.
 - 3. MR Credit 6: Rapidly Renewable Materials.
 - 4. MR Credit 7: Certified Wood.
 - 5. EQ Credit 4.4: Low-Emitting Materials - Composite Wood and Agrifiber Products.
- H. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- I. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Tolerances for Warp, Telegraphing, Squareness, and Prefitting Dimensions: WDMA I.S.1-A.
- B. Identifying Label: Each door shall bear identifying label indicating:
 - 1. Door manufacturer.
 - 2. Order number.
 - 3. Door number.
 - 4. Fire rating, if applicable.

Specifier Notes: Delete the following paragraph if fire-rated doors are not required.

- C. Fire-Rated Doors: Labeled by Intertek/Warnock Hersey.
 - 1. Construction Details and Hardware Application: Approved by labeling agency.

Specifier Notes: Edit the following paragraph as required. Delete if positive pressure opening assemblies are not required.

- D. Positive Pressure Opening Assemblies: UBC 7-2-1997/UL 10C.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- E. Environmental Responsibility: Provide doors manufactured with the following environmentally responsible components:

Specifier Notes: Include the sentences for each specified component.

1. Core:
 - a. Agrifiber Core:
 - 1) Rapidly renewable materials.
 - 2) Pre-consumer recycled content.
 - 3) No added urea formaldehyde.
 - b. Particleboard Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) Pre-consumer recycled material.
 - 3) No added urea formaldehyde.
 - c. Stave Lumber Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
 - d. Structural Composite Lumber (SCL) Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
2. Composite Crossband:
 - a. High-Density Fiberboard (HDF):
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) Pre-consumer recycled material.
 - 3) No added urea formaldehyde.
3. Stiles and Rails:
 - a. Structural Composite Lumber (SCL): No added urea formaldehyde.
4. Veneer Face: Forest Stewardship Council (FSC) certified, as available.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Delivery:

1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.

B. Storage:

1. Store doors in accordance with manufacturer's instructions.
2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
3. Store doors flat on level surface.
4. Do not store doors directly on concrete.
5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 30 to 50 percent relative humidity.

C. Handling:

1. Handle doors in accordance with manufacturer's instructions.
2. Protect doors and finish during handling and installation to prevent damage.
3. Handle doors with clean hands or clean gloves.
4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 ENVIRONMENTAL REQUIREMENTS

- A. Do not subject doors to extreme conditions or changes in temperature or relative humidity in accordance with AWS.

1.8 WARRANTY

- A. Warrant solid core, interior doors for life of installation against warpage, delamination, and defects in materials and workmanship.
- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehanging as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 890 Central Court, New Albany, Indiana 47150. Toll Free (800) 626-6271. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 GENERAL

Specifier Notes: Glass mouldings can be provided in a variety of wood species and profiles from non-rated to 90-minute rated. Consult VT Industries for more information.

- A. Glass Mouldings:
 - 1. Non-rated Flush Doors: VT Industries standard profiles.
 - 2. Fire-Rated Doors: VT Industries Style 110, steel vision frame, beige prime finish.
- B. Glazing: As specified in Section 08800 (08 80 00).
- C. Door Louvers: As specified in Section 10225 (08 91 26).

2.3 FIVE-PLY FLUSH BONDED DOORS

- A. Five-Ply Flush Bonded Doors: Artistry Collection.

Specifier Notes: Specify the Artistry Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

- 1. Model:
 - a. [5502A, PC-5, PC-20-5, and PC-20PP-5, particleboard core, non-rated and 20-minute rated, positive pressure.]
 - b. [5P02A, PC-20PP-5, particleboard core, 20-minute rated, positive pressure.]
 - c. [5509A, WSPC-5, WSPC-20-5, and WSPC-20PP-5, agrifiber core, non-rated and 20-minute rated, positive pressure.]
 - d. [5P09A, WSPC-20PP-5, agrifiber core, 20-minute rated, positive pressure.]

- e. [5508A, SCLC-5, SCLC-20-5, and SCLC-20PP-5, structural composite lumber, non-rated and 20-minute rated, positive pressure.]
 - f. [5P08H, SCLC-20PP-5, structural composite lumber, 20-minute rated, positive pressure.]
 - g. [5507A, SLC-5, SLC-20-5, and SLC-20PP-5, stave lumber core, non-rated and 20-minute rated, positive pressure.]
 - h. [5P07A, SLC-20PP-5, stave lumber core, 20-minute rated, positive pressure.]
 - i. [HC-5, hollow core, non-rated.]
2. Compliance: AWS Section 9.
 - a. Aesthetic Grade: Premium.
 - b. Duty Level: Extra heavy duty.
 - c. Type: PC-5, WSPC-5, SCLC-5, SLC-5, HC-5.
 3. Seven-Ply and Non-Bonded Core Construction: Not acceptable.

Specifier Notes: Specify door thickness.

4. Door Thickness: [1-3/4 inches] [_____ inches].
5. Stiles:
 - a. Inner Stiles: Structural Composite Lumber (SCL).
 - b. Outer Stiles: Same species as face veneer.
6. Rails:
 - a. Structural composite lumber (SCL).
 - b. Minimum Width Before Prefitting: 1-3/4 inches.
7. Core:

Specifier Notes: Specify the core material.

- a. Material: [Particleboard] [Agrifiber] [Structural composite lumber (SCL)] [Stave lumber] [Hollow core].
 - b. Particleboard and Agrifiber: ANSI A208.1, Grade 1-LD-2.
 - c. Stave Lumber Core: Blocks and strips not more than 2-1/2 inches wide, one species of wood.
 - d. Structural Composite Lumber Core: WDMA I.S. 10.
 - e. Hollow Core: WDMA 1.S. 10.
8. Door Assembly:
 - a. Stiles and rails bonded to core.
 - b. Sand entire assembly flat as a unit to ensure minimal telegraphing of core components through face veneers.
 9. Composite Crossbands: Apply to core in hot press using Type II, water-resistant adhesive after application of hardwood edges.
 10. Veneers:
 - a. Apply to crossbanded core in hot press using Type II, water-resistant adhesive.

Specifier Notes: Specify the veneers species, cut, match, and assembly.

- b. Species: _____ .
- c. Cut: [Rotary] [Plain sliced] [Quarter] [_____].

- d. Match: [Book] [Slip].
 - e. Assembly: [Running] [Balanced] [Center balanced].
 - f. Minimum Thickness Before Sanding: 1/42 inch.
11. Positive Pressure:
- a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter and between door and pairs to meet Smoke (S) rating.
 - c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

2.4 FLUSH FIRE-RATED WOOD DOORS

- A. Flush Fire-Rated Wood Doors: Artistry Collection.

Specifier Notes: Specify the Artistry Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [5545A, FD-45-5, mineral core, 45-minute rated, positive pressure.]
 - b. [5P45A, FD-45PP-5 and FD-60PP-5, mineral core, 45- and 60-minute rated, positive pressure.]
 - c. [5511A, FD-45-5, FD-60-5, and FD-90-5, mineral core, 45-, 60-, and 90-minute rated, positive pressure.]
 - d. [5P11A, FD-60PP-5 and FD-90PP-5, mineral core, 60- and 90-minute rated, positive pressure.]
 - e. [5P08A, FD-45PP-5, structural composite lumber core, 45-minute rated, positive pressure.]
 - f. [5P09A, FD-45PP-5 and FD-60PP-5, agrifiber core, 45- and 60-minute rated, positive pressure.]
2. Compliance: AWS Section 9.
 - a. Grade: Premium.
 - b. Type: FD-5.

Specifier Notes: Specify door thickness.

3. Door Thickness: [1-3/4 inches] [_____ inches].
4. Outer Stiles: Same species as face veneer.

Specifier Notes: Specify required inner stiles.

5. Inner Stiles: [Structural composite lumber (SCL), 45-minute rated] [Noncombustible material, 60- and 90-minute rated].

Specifier Notes: Specify required rails.

6. Rails:
 - a. [Structural composite lumber (SCL), 45-minute rated] [Noncombustible material, 60- and 90-minute rated].
 - b. Width: Manufacturer's standard width.
7. Core:
 - a. Fire-Retardant Mineral Core: Does not contain asbestos or added urea formaldehyde.
 - b. Agrifiber Core Door: ANSI A208.1, Grade 1-LD-2.
 - c. Structural Composite Lumber Core: WDMA I.S. 10.
8. Composite Crossbands: Apply to core in hot press using Type II, water-resistant adhesive after application of hardwood edges.
9. Veneers:
 - a. Apply to crossbanded core in hot press using Type II, water-resistant adhesive.

Specifier Notes: Specify the veneers species, cut, match, and assembly.

- b. Species: _____.
- c. Cut: [Rotary] [Plain sliced] [Quarter] [_____].
- d. Match: [Book] [Slip].
- e. Assembly: [Running] [Balanced] [Center balanced].
- f. Minimum Thickness Before Sanding: 1/42 inch.
10. Positive Pressure:
 - a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter to meet S-rating.
 - c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

2.5 LEAD-LINED DOORS

- A. Lead-Lined Doors: Artistry Collection.

Specifier Notes: Specify the Artistry Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [5515A, structural composite lumber core, LL-7, non-rated.]
 - b. [5P15A, structural composite lumber core, LL-20PP-7, 20-minute rated, positive pressure.]
2. Compliance: AWS Section 9.
 - a. Grade: Premium.
3. Non-Rated and 20-Minute-Rated Fire Doors with Lead:
 - a. Door Thickness: 1-3/4 inches.
 - b. Maximum Lead Thickness: 1/4 inch.

4. Core:
 - a. Structural Composite Lumber (SCL): WDMA I.S. 10.
5. Face Veneers and Vertical Stile Edges: Compatible with non-rated and fire-rated doors.
6. Composite Crossbands: Apply to core in hot press using Type II, water-resistant adhesive after application of hardwood edges.
7. Stiles:
 - a. Inner Stiles: Structural Composite Lumber (SCL).
 - b. Outer Stiles: 7/8 inch wide, same species as face veneer.
8. Rails: Structural composite lumber (SCL).
9. Lead-Lined Steel Lite Frames on 20-Minute Doors:
 - a. Maximum Lite Opening Size: 40 percent of door area or 50 percent of door height, 5-inch minimum between cutouts and door edge.
10. Lead Lining:

Specifier Notes: Edit the following sentence if a shielding study is not provided by the Owner.

- a. Thickness: Conform to shielding study provided by Owner.

2.6 FABRICATION

- A. Prefit Doors:
 1. Prefit and bevel doors at factory to fit openings.
 2. Prefit Tolerances: WDMA I.S.1-A and AWS Section 9.
- B. Factory-machine doors for mortised hardware, including pilot holes for hinge screws and lock fronts required.

2.7 FINISHES

- A. Doors shall receive factory finishing.
- B. Factory Finishing: AWS System 2, precatalyzed lacquer.

Specifier Notes: Omit the stain coat if a clear finish is desired.

1. Stain coat.
2. Sealer coat.
3. Sanding: sand.
4. Topcoat: 2 coats.

Specifier Notes: Specify the stain color. Consult VT Industries for custom stain and paint colors and for minimum size of physical sample required for custom color matching.

- C. Stain Color: [Clear] [Alpine] [Grassland] [Oasis] [Ravine] [Savanna] [Timber] [Wheat] [_____].
- D. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.
- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust hardware to operate properly.
- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

- A. Protect installed doors from damage during construction.

END OF SECTION

VT Industries, Inc.
1000 Industrial Park
PO Box 490
Holstein, Iowa 51025
Toll Free (800) 827-1615
Phone (712) 368-4381
Fax (712) 368-4111
Website www.vtindustries.com
E-mail door_info@vtindustries.com

May 2010

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all "Specifier Notes" when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08212 (08 14 16)

FLUSH WOOD VENEER DOORS

Specifier Notes: This section covers VT Industries Heritage Collection interior flush wood veneer doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Interior Flush Wood Veneer Doors:

Specifier Notes: Edit the following list as required.

1. Five-ply flush bonded doors.
2. Flush fire-rated wood doors.
3. Lead-lined doors.

4. Sound-retardant doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.
- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.
- D. Section 08800 (08 80 00) – Glazing.
- E. Section 10225 (08 91 26) – Door Louvers.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. ANSI A208.1 – Particleboard.
- B. ASTM E 90 – Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
- C. ASTM E 413 – Classification for Rating Sound Insulation.
- D. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 – Doors.
- E. NFPA 80 – Standard for Fire Doors and Other Opening Protectives.
- F. UBC 7-2-1997/UL 10C – Positive Pressure Fire Tests of Door Assemblies.
- G. WDMA Finish System TR-6, Catalyzed Polyurethane.
- H. WDMA I.S. 1A – Architectural Wood Flush Doors.
- I. WDMA I.S. 10 – Industry Standard for Testing Cellulosic Composite Materials for Use in Fenestration Products.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.

- B. Product Data: Submit manufacturer's product data, including door construction description and WDMA I.S.1-A and AWS classifications.
- C. Schedules: Submit manufacturer's schedules, including door dimensions, cutouts, species, finish, and hardware. Reference individual door numbers as indicated on the Drawings.
- D. Samples: Submit manufacturer's door finish samples, showing range of color variation.

Specifier Notes: Include the following paragraph when specifying sound-retardant doors.

- E. Test Reports: Submit manufacturer's test results of STC ratings from testing performed by independent testing agency for sound-retardant doors.
- F. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- G. Environmental Documentation: Submit manufacturer's environmental documentation for the following LEED credits.
 - 1. MR Credit 4: Recycled Content.
 - 2. MR Credit 5: Regional Materials.
 - 3. MR Credit 6: Rapidly Renewable Materials.
 - 4. MR Credit 7: Certified Wood.
 - 5. EQ Credit 4.4: Low-Emitting Materials - Composite Wood and Agrifiber Products.
- H. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- I. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Tolerances for Warp, Telegraphing, Squareness, and Prefitting Dimensions: WDMA I.S.1-A.
- B. Identifying Label: Each door shall bear identifying label indicating:
 - 1. Door manufacturer.
 - 2. Order number.
 - 3. Door number.
 - 4. Fire rating, if applicable.

Specifier Notes: Delete the following paragraph if fire-rated doors are not required.

- C. Fire-Rated Doors: Labeled by Intertek/Warnock Hersey.
 - 1. Construction Details and Hardware Application: Approved by labeling agency.

Specifier Notes: Edit the following paragraph as required. Delete if positive pressure opening assemblies are not required.

D. Positive Pressure Opening Assemblies: UBC 7-2-1997/UL 10C.

Specifier Notes: Include the following paragraph for projects requiring LEED or other green building certification.

E. Environmental Responsibility: Provide doors manufactured with the following environmentally responsible components:

Specifier Notes: Include the sentences for each specified component.

1. Core:
 - a. Agrifiber Core:
 - 1) Rapidly renewable materials.
 - 2) Pre-consumer recycled content.
 - 3) No added urea formaldehyde.
 - b. Particleboard Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) Pre-consumer recycled material.
 - 3) No added urea formaldehyde.
 - c. Stave Lumber Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
 - d. Structural Composite Lumber (SCL) Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
2. Composite Crossband:
 - a. High-Density Fiberboard (HDF):
 - 1) Pre-consumer recycled material.
 - 2) No added urea formaldehyde.
3. Stiles and Rails:
 - a. Structural Composite Lumber (SCL): No added urea formaldehyde.
4. Veneer Face:
 - a. Forest Stewardship Council (FSC) certified.
5. GREENGUARD Certification Program.
 - a. GREENGUARD Indoor Air Quality Certified.
 - b. GREENGUARD Children and Schools Certified.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
 2. Package doors individually in polybags.

- B. Storage:
 - 1. Store doors in accordance with manufacturer's instructions.
 - 2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
 - 3. Store doors flat on level surface.
 - 4. Do not store doors directly on concrete.
 - 5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
 - 6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 30 to 50 percent relative humidity.

- C. Handling:
 - 1. Handle doors in accordance with manufacturer's instructions.
 - 2. Protect doors and finish during handling and installation to prevent damage.
 - 3. Handle doors with clean hands or clean gloves.
 - 4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 ENVIRONMENTAL REQUIREMENTS

- A. Do not subject doors to extreme conditions or changes in temperature or relative humidity in accordance with WDMA I.S.1-A.

1.8 WARRANTY

- A. Warrant solid core, interior doors for life of installation against warpage, delamination, and defects in materials and workmanship.

- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehanging as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 1000 Industrial Park, PO Box 490, Holstein, Iowa 51025. Toll Free (800) 827-1615. Phone (712) 368-4381. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 GENERAL

Specifier Notes: Glass mouldings can be provided in a variety of wood species and profiles from non-rated to 90-minute rated. Consult VT Industries for more information.

- A. Glass Mouldings:
 - 1. Non-rated Flush Doors: VT Industries Style VT1.
 - 2. Fire-Rated Doors: VT Industries Style 110, steel vision frame, beige prime finish.

- B. Glazing: As specified in Section 08800 (08 80 00).

C. Door Louvers: As specified in Section 10225 (08 91 26).

2.3 FIVE-PLY FLUSH BONDED DOORS

A. Five-Ply Flush Bonded Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [5502H, PC-5, PC-20-5, and PC-20PP-5, particleboard core, non-rated and 20-minute rated, positive pressure.]
 - b. [5P02H, PC-20PP-5, particleboard core, 20-minute rated, positive pressure.]
 - c. [5509H, WSPC-5, WSPC-20-5, and WSPC-20PP-5, agrifiber core, non-rated and 20-minute rated, positive pressure.]
 - d. [5P09H, WSPC-20PP-5, agrifiber core, 20-minute rated, positive pressure.]
 - e. [5508H, SCLC-5, SCLC-20-5, and SCLC-20PP-5, structural composite lumber, non-rated and 20-minute rated, positive pressure.]
 - f. [5P08H, SCLC-20PP-5, structural composite lumber, 20-minute rated, positive pressure.]
 - g. [5507H, SLC-5, SLC-20-5 and SLC-20PP-5, stave lumber core, non-rated and 20-minute rated, positive pressure.]
 - h. [5P07H, SLC-20PP-5, stave lumber core, 20-minute rated, positive pressure.]
2. Compliance: WDMA I.S.1-A.
 - a. Aesthetic Grade: Premium grade.
 - b. Duty Level: Extra heavy duty.
 - c. Type: PC-5, WSPC-5, SCLC-5, SLC-5.
3. Seven-Ply and Non-Bonded Core Construction: Not acceptable.
4. Door Thickness: 1-3/4 inches.
5. STC Rating:
 - a. Model 5502H/5P02H: STC 31, STC 32 with lite 100 to 256 square inches.
 - b. Model 5509H/5P09H: STC 30, non-rated and 20-minute rated.
 - c. Model 5508H/5P08H: STC 33.
 - d. Model 5507H/5P07H: STC 32.
6. Stiles:
 - a. Inner Stiles: 1-3/8 inches wide, before prefitting.
 - b. Structural Composite Lumber (SCL) With Outer Stile: Same species as face veneer.
 - c. Outer Stile: Apply after beveling and before face application.
7. Rails:
 - a. Structural composite lumber (SCL).
 - b. Minimum Width Before Prefitting: 1-3/8 inches.
8. Core:

Specifier Notes: Specify the core material.

- a. Material: [Particleboard] [Agrifiber] [Structural composite lumber (SCL)] [Stave lumber].
- b. Particleboard and Agrifiber Compliance: ANSI A208.1, Grade 1-LD-2.

- c. Stave Lumber Core Compliance: Blocks and strips not more than 2-1/2 inches wide, one species of wood.
- d. Structural Composite Lumber Core Compliance: WDMA I.S. 10.
- 9. Door Assembly:
 - a. Stiles and Rails: Bonded to core.
 - b. Sand entire assembly flat as a unit to ensure minimal telegraphing of core components through face veneers.
- 10. Composite Crossbands:
 - a. Apply to core in hot press using Type I, exterior, water-resistant adhesive, before application of hardwood edges.
 - b. Exposed Crossbanding: Not allowed along stile edges.
- 11. Veneers:
 - a. Apply to crossbanded core in hot press using Type I, exterior, water-resistant adhesive.

Specifier Notes: Specify the veneer species, cut, match, and assembly.

- b. Species: _____ .
- c. Cut: [Rotary] [Plain sliced] [Quarter] [_____].
- d. Match: [Book] [Slip].
- e. Assembly: [Running] [Balanced] [Center balanced].
- f. Minimum Thickness Before Sanding: 1/42 inch.
- 12. Positive Pressure:
 - a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter and between door and pairs to meet Smoke (S) rating.
 - c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

Specifier Notes: The 2007 edition of NFPA 80 requires an annual inspection by the building owner of all fire-rated door assemblies classified as swinging doors with builders' hardware. VT Industries, Inc. "VTsmartdoor™" barcode technology will make the Owner's fire-rated door assembly inspections easier. Consult VT Industries, Inc. for more information.

- 13. Electronic Barcode: "VTsmartdoor" barcode technology.
 - a. Location: Fire label, hinge stile of doors.
 - b. Provide fire-rated door assembly information required for Owner's annual fire-door inspection in accordance with NFPA 80, Paragraph 5.2.1.

2.4 FLUSH FIRE-RATED WOOD DOORS

- A. Flush Fire-Rated Wood Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [5545H, FD-45-5, mineral core, 45-minute rated, positive pressure.]
 - b. [5P45H, FD-45PP-5 and FD-60PP-5, mineral core, 45- and 60-minute rated, positive pressure.]
 - c. [5511H, FD-45-5, FD-60-5, and FD-90-5, mineral core, 45-, 60-, and 90-minute rated, positive pressure.]
 - d. [5P11H, FD-60PP-5 and FD-90PP-5, mineral core, 60- and 90-minute rated, positive pressure.]
 - e. [5P08H, FD-45PP-5, structural composite lumber core, 45-minute rated, positive pressure.]
 - f. [5P09H, FD-45PP-5 and FD-60PP-5, agrifiber core, 45- and 60-minute rated, positive pressure.]
2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
 - b. Type: FD-5.
3. Door Thickness: 1-3/4 inches.
4. STC Rating:
 - a. Mineral/Structural Composite Lumber Core: STC 33.
 - b. Agrifiber Core: STC 30.
5. Outer Edges: Same species as face veneer.

Specifier Notes: Specify required inner stiles.

6. Inner Stiles: [Structural composite lumber (SCL), 45-minute rated] [Noncombustible material, 60- and 90-minute rated].

Specifier Notes: Specify required rails.

7. Rails:
 - a. [Structural composite lumber (SCL), 45-minute rated] [Noncombustible material, 60- and 90-minute rated].
 - b. Width: Manufacturer's standard width.
8. Core:
 - a. Fire-Retardant Mineral Core: Does not contain asbestos or added urea formaldehyde.
 - b. Agrifiber Core Door: ANSI A208.1, Grade 1-LD-2.
 - c. Structural Composite Lumber Core: WDMA I.S. 10.
9. Composite Crossbands:
 - a. Apply to core in hot press using Type I, exterior, water-resistant adhesive before application of hardwood edges.
 - b. Exposed Crossbanding: Not allowed along stile edges.
10. Veneers:
 - a. Apply to crossbanded core in hot press using Type I, exterior, water-resistant adhesive.

Specifier Notes: Specify the veneers species, cut, match, and assembly.

- b. Species: _____ .
 - c. Cut: [Rotary] [Plain sliced] [Quarter] [_____].
 - d. Match: [Book] [Slip].
 - e. Assembly: [Running] [Balanced] [Center balanced].
 - f. Minimum Thickness Before Sanding: 1/42 inch.
11. Positive Pressure:
- a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter and between door and pairs to meet Smoke (S) rating.
 - c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

Specifier Notes: The 2007 edition of NFPA 80 requires an annual inspection by the building owner of all fire-rated door assemblies classified as swinging doors with builders' hardware. VT Industries, Inc. "VTsmartdoor™" barcode technology will make the Owner's fire-rated door assembly inspections easier. Consult VT Industries, Inc. for more information.

12. Electronic Barcode: "VTsmartdoor" barcode technology.
- a. Location: Fire label, hinge stile of doors.
 - b. Provide fire-rated door assembly information required for Owner's annual fire-door inspection in accordance with NFPA 80, Paragraph 5.2.1.

2.5 LEAD-LINED DOORS

A. Lead-Lined Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

- 1. Model:
 - a. [5515-2, particleboard core, LL-7, non-rated.]
 - b. [5P15-2, particleboard core, LL-20PP-7, 20-minute rated, positive pressure.]
- 2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
- 3. Non-Rated and 20-Minute-Rated Fire Doors With Lead Sheet on Both Sides of Core:
 - a. Door Thickness: 1-3/4 inches.
 - b. Maximum Combined Lead Thickness: 1/4 inch.
- 4. Core:
 - a. Particleboard.
 - b. Grade: 1-LD-2, for lead-each-side construction.
- 5. Composite Crossbands:
 - a. Apply to core before application of matching hardware stiles.

- b. Exposed Crossbanding: Not allowed along stile edges.
- 6. Stiles:
 - a. Inner Stiles: 1-3/8 inches wide, before prefitting.
 - b. Structural Composite Lumber (SCL) with matching edge.
- 7. Rails:
 - a. Structural composite lumber (SCL).
 - b. Width: 1-3/8 inches.
- 8. Lead-Lined Steel Lite Frames on 20-Minute Doors:
 - a. Maximum Lite Opening Size: 256 square inches.
 - b. Maximum Width and Height: 16 inches.
- 9. Lead Lining:

Specifier Notes: Edit the following sentence if a shielding study is not provided by the Owner.

- a. Thickness: Conform to shielding study provided by Owner.

2.6 SOUND-RETARDANT DOORS

- A. Sound-Retardant Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

- 1. Model:
 - a. [5540H, composite sound core, SR-5, stained stiles.]
 - b. [5550H, sound attenuation core, SR-5, stained stiles.]
 - c. [5P50H, sound attenuation core, SR-20PP-5, stained stiles, positive pressure.]
 - d. [5050H, sound attenuation core, SR-5, stained stiles.]
 - e. [5P40H, composite sound core, SR-20PP-5, stained stiles, positive pressure.]
- 2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
- 3. Testing Methods: ASTM E 90 and E 413.
- 4. Door Thickness: 1-3/4 inches.

Specifier Notes: Specify the STC rating. Consult VT Industries for assistance in choosing the STC rating for the specific application.

- 5. STC Rating: [39] [45] [48] [49] [50] [51] [52].
- 6. Core: Sound absorbent material encapsulated by stiles, rails, crossbands, and face veneers.
- 7. Perimeter Gasketing and Drop Seals: To achieve STC ratings.
- 8. STC Frames: Required for STC 48 and above.
- 9. Face Veneers and Vertical Stile Edges: Matching.

Specifier Notes: Delete the acoustical lite kit if a lite is not required in the door. Using the Model 105 acoustical lite kit, STC 39 doors can maintain the full acoustical rating. The maximum lite size to meet these requirements is 216 square inches or a maximum of 6 inches wide by 36 inches long.

10. Acoustical Lite Kit: [Model 105 for STC 39] [Model 105 for STC 44].

2.7 FABRICATION

A. Prefit Doors:

1. Prefit and bevel doors at factory to fit openings.
2. Prefit Tolerances: WDMA I.S.1-A and AWS Section 9.

B. Factory-machine doors for mortised hardware, including pilot holes for hinge screws and lock fronts required.

2.8 FINISHES

A. Doors shall receive factory finishing.

Specifier Notes: Specify the factory finishing.

B. Factory Finishing: [WDMA System TR-6, catalyzed polyurethane, premium grade] [Powder coat].

Specifier Notes: Omit the stain coat if a clear finish is desired.

1. Stain coat.
2. Sealer: 3 coats.
3. Sanding: Sand.
4. Topcoat: 2 coats.

Specifier Notes: Specify the stain color. Consult VT Industries for custom stain and paint colors and for minimum size of physical sample required for custom color matching.

C. Stain Color: [Clear] [Alpine] [Grassland] [Oasis] [Ravine] [Savanna] [Timber] [Wheat] [_____].

Specifier Notes: Include the following sentence if powder-coat factory finish is specified. Specify the powder coat color. Consult VT Industries for minimum size of physical sample required for custom color matching.

D. Powder Coat Color: [Black] [Dover White] [Lapis Blue] [Stop Red] [White Sand] [_____].

E. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.
- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust hardware to operate properly.
- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

A. Protect installed doors from damage during construction.

END OF SECTION

VT Industries, Inc.
890 Central Court
New Albany, Indiana 47150
Toll Free (800) 626-6271
Fax (712) 368-4111
Website www.vtindustries.com
E-mail door_info@vtindustries.com

May 2010

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all “Specifier Notes” when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08212 (08 14 17)

ROUTED-FACE PROFILED DOORS

Specifier Notes: This section covers VT Industries Heritage Collection interior routed-face profiled doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Interior routed-face profiled doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.

- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. ANSI A208.2 – Medium Density Fiberboard (MDF) for Interior Applications.
- B. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 – Doors.
- C. NFPA 80 – Standard for Fire Doors and Other Opening Protectives.
- D. UBC 7-2-1997/UL 10C – Positive Pressure Fire Tests of Door Assemblies.
- E. WDMA I.S.1-A – Architectural Wood Flush Doors.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data, including:
 - 1. Door construction description.
 - 2. WDMA I.S.1-A classification.
 - 3. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 classification.
- C. Schedules: Submit manufacturer's schedules, including door dimensions, cutouts, species, finish, and hardware. Reference individual door numbers as indicated on the Drawings.
- D. Samples: Submit manufacturer's door finish samples, showing range of color variation.
- E. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- F. Environmental Documentation: Submit manufacturer's environmental documentation for the following LEED credits.

Specifier Notes: Include the sentence for the specified core construction.

- 1. MR Credit 4: Recycled Content.
- 2. MR Credit 7: Certified Wood.
- 3. EQ Credit 4.4: Low-Emitting Materials - Composite Wood and Agrifiber Products.

- G. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- H. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Tolerances for Warp, Telegraphing, Squareness, and Prefitting Dimensions: WDMA I.S.1-A.
- B. Identifying Label: Each door shall bear identifying label indicating:
 - 1. Door manufacturer.
 - 2. Order number.
 - 3. Door number.
 - 4. Fire rating, if applicable.

Specifier Notes: Delete the following paragraph if fire-rated doors are not required.

- C. Fire-Rated Doors: Labeled by Intertek/Warnock Hersey.
 - 1. Construction Details and Hardware Application: Approved by labeling agency.

Specifier Notes: Edit the following paragraph as required. Delete if positive-pressure opening assemblies are not required.

- D. Positive-Pressure Opening Assemblies: UBC 7-2-1997/UL 10C.
- E. Environmental Responsibility: Provide doors manufactured with the following environmentally responsible components:

Specifier Notes: Include the sentences for each specified component.

- 1. Core:
 - a. Medium-Density Fiberboard (MDF):
 - 1) Pre-consumer recycled content.
 - 2) No added urea formaldehyde.
 - 3) Forest Stewardship Council (FSC) certified.
- 2. Stiles and Rails:
 - a. Structural Composite Lumber (SCL): No added urea formaldehyde.
- 3. Face:
 - a. High-Density Fiberboard (HDF):
 - 1) Pre-consumer recycled material.
 - 2) No added urea formaldehyde.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
 - 1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.

2. Package doors individually in polybags.

B. Storage:

1. Store doors in accordance with manufacturer's instructions.
2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
3. Store doors flat on level surface.
4. Do not store doors directly on concrete.
5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 30 to 50 percent relative humidity.

C. Handling:

1. Handle doors in accordance with manufacturer's instructions.
2. Protect doors and finish during handling and installation to prevent damage.
3. Handle doors with clean hands or clean gloves.
4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 ENVIRONMENTAL REQUIREMENTS

- A. Do not subject doors to extreme conditions or changes in temperature or relative humidity in accordance with WDMA I.S.1-A.

1.8 WARRANTY

- A. Length of Warranty for Solid Core, Interior Doors: 5 years against warpage, delamination, and defects in materials and workmanship.
- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehanging as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 890 Central Court, New Albany, Indiana 47150. Toll Free (800) 626-6271. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 ROUTED-FACE PROFILED DOORS

- A. Interior Routed-Face Profiled Doors: Heritage Collection.

Specifier Notes: Specify the door elevation. Consult VT Industries for availability and options for Heritage Collection custom routed-face profiled doors.

1. Elevation: [FS1011H] [FS1021H] [FS1031H] [FS1041H] [FS1042H] [FS1052H] [FS1062H] [FA1021H] [FA1031H] [FA1032H] [FC1011H] [FC1021H] [FC1031H] [FC1032H].

2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium grade, heavy duty.

Specifier Notes: Specify the routing profile.

3. Routing Profile: [VT 2] [VT 3] [VT 4].
4. Core: Medium-density fiberboard (MDF), ANSI A208.2.
5. Face: High-density fiberboard (HDF), ANSI A208.2.
6. Inner Stiles and Rails: Structural composite lumber (SCL).
 - a. Width: 1-3/8 inches before prefitting.

Specifier Notes: Specify the outer edge finish.

7. Outer Edges: [HDF, primed] [HDF, powder coat].
 - a. Apply before face application.
8. Face Dimensions:
 - a. Stiles: 6 inches.
 - b. Top Rail: 6 inches.
 - c. Bottom Rail: 10 inches.
 - d. Intermediate Rails: 4 inches or 6 inches.
 - e. Vertical Mullions: 4 inches.
 - f. Thickness: 1-3/4 inches.

Specifier Notes: Include the following paragraph for Heritage Collection fire-rated routed-face profiled doors.

- B. Fire-Rated Routed-Face Profiled Doors: Heritage Collection.
 1. 20-Minute, Positive-Pressure, Fire-Rated Doors:
 - a. Maximum Size:
 - 1) Single: 4'-0" by 8'-0".
 - 2) Paired: 8'-0" by 8'-0".

Specifier Notes: Specify the type of lock.

- b. Locks: [Mortise] [Cylindrical].
- c. Flush bolts.
2. Positive Pressure:
 - a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Intertek/Warnock Hersey Category A guidelines.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter to meet S-rating.
 - c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

Specifier Notes: The 2007 edition of NFPA 80 requires an annual inspection by the building owner of all fire-rated door assemblies classified as swinging doors with builders' hardware. VT Industries, Inc. "VTsmartdoor™" barcode technology will make the Owner's fire-rated door assembly inspections easier. Consult VT Industries, Inc. for more information.

3. Electronic Barcode: "VTsmartdoor" barcode technology.
 - a. Location: Fire label, hinge stile of doors.
 - b. Provide fire-rated door assembly information required for Owner's annual fire-door inspection in accordance with NFPA 80, Paragraph 5.2.1.

2.3 FABRICATION

- A. Prefit Doors:
 1. Prefit and bevel doors at factory to fit openings.
 2. Prefit Tolerances: WDMA I.S.1-A and AWI/AWMAC/WI Architectural Woodwork Standards, Section 9.
- B. Factory-machine doors for mortised hardware, including pilot holes for hinge screws and lock fronts.

2.4 FINISHES

- A. Doors: Factory finish.

Specifier Notes: Specify the factory finish. Primed finish is standard.

- B. Factory Finish: [Primed] [Powder coat].

Specifier Notes: Include the following sentence if powder-coat factory finish is specified. Specify the powder coat color. Consult VT Industries for minimum size of physical sample required for custom color matching.

- C. Powder Coat Color: [Black] [Dover White] [Lapsis Blue] [Stop Red] [White Sand] [_____].
- D. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors.
 1. Notify Architect of conditions that would adversely affect installation or subsequent use.
 2. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.

- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust door hardware to operate properly.
- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

- A. Protect installed doors from damage during construction.

END OF SECTION

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings.

Delete all "Specifier Notes" when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08214 (08 14 23.16)

HIGH-PRESSURE DECORATIVE LAMINATE FACED DOORS

Specifier Notes: This section covers VT Industries Heritage Collection high-pressure decorative laminate faced doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Interior High-Pressure Decorative Laminate Faced Doors:

Specifier Notes: Edit the following list as required.

1. Flush solid-core high-pressure decorative laminate doors.
2. Flush fire-rated high-pressure decorative laminate doors.
3. Lead-lined doors.
4. Sound-retardant doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.
- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.
- D. Section 08800 (08 80 00) – Glazing.

- E. Section 10225 (08 91 26) – Door Louvers.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. ANSI A208.1 – Particleboard.
- B. ASTM E 90 – Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
- C. ASTM E 413 – Classification for Rating Sound Insulation.
- D. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 – Doors.
- E. NEMA LD3 – High Pressure Decorative Laminates.
- F. NFPA 80 – Standard for Fire Doors and Other Opening Protectives.
- G. UBC 7-2-1997/UL 10C – Positive Pressure Fire Tests of Door Assemblies.
- H. WDMA I.S.1-A – Architectural Wood Flush Doors.
- I. WDMA I.S. 10 – Industry Standard for Testing Cellulosic Composite Materials for Use in Fenestration Products.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data, including door construction description and WDMA I.S.1-A and AWS classifications.
- C. Schedules: Submit manufacturer's schedules, including door dimensions, cutouts, high-pressure decorative laminate selection, and hardware. Reference individual door numbers as indicated on the Drawings.
- D. Samples:
 - 1. Submit manufacturer's door construction samples for door model specified.
 - 2. Submit manufacturer's sample chip with color and finish number.

Specifier Notes: Include the following paragraph when specifying sound-retardant doors.

- E. Test Reports: Submit manufacturer's test results of STC ratings from testing performed by independent testing agency for sound-retardant doors.
- F. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- G. Environmental Documentation: Submit manufacturer's environmental documentation for the following LEED credits.

Specifier Notes: Include the sentence for the specified core construction.

1. MR Credit 4: Recycled Content.
2. MR Credit 5: Regional Materials.
3. MR Credit 6: Rapidly Renewable Materials.
4. MR Credit 7: Certified Wood.
5. EQ Credit 4.4: Low-Emitting Materials - Composite Wood and Agrifiber Products.

- H. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- I. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Tolerances for Warp, Telegraphing, Squareness, and Prefitting Dimensions: WDMA I.S.1-A and AWS.
- B. Identifying Label: Each door shall bear identifying label indicating:
 1. Door manufacturer.
 2. Order number.
 3. Door number.
 4. Fire rating, if applicable.

Specifier Notes: Delete the following paragraph if fire-rated doors are not required.

- C. Fire-Rated Doors: Labeled by Intertek/Warnock Hersey.
 1. Construction Details and Hardware Application: Approved by labeling agency.

Specifier Notes: Edit the following paragraph as required. Delete if positive pressure opening assemblies are not required.

- D. Positive Pressure Opening Assemblies: UBC 7-2-1997/UL 10C.

Specifier Notes: Include the following paragraph for projects requiring LEED certification.

- E. Environmental Responsibility: Provide doors manufactured with the following environmentally responsible components:

Specifier Notes: Include the sentences for each specified component.

1. Core:
 - a. Agrifiber Core:
 - 1) Rapidly renewable materials.
 - 2) Pre-consumer recycled content.
 - 3) No added urea formaldehyde.
 - b. Particleboard Core:

- 1) Forest Stewardship Council (FSC) certified.
 - 2) Pre-consumer recycled material.
 - 3) No added urea formaldehyde.
 - c. Stave Lumber Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
 - d. Structural Composite Lumber (SCL) Core:
 - 1) Forest Stewardship Council (FSC) certified.
 - 2) No added urea formaldehyde.
- 2. Composite Crossband:
 - a. High-Density Fiberboard (HDF):
 - 1) Pre-consumer recycled material.
 - 2) No added urea formaldehyde.
- 3. Stiles and Rails:
 - a. Structural Composite Lumber (SCL): No added urea formaldehyde.
- 4. HPDL Face:
 - a. Forest Stewardship Council (FSC) certified, as available.
 - b. GREENGUARD Indoor Air Quality Certified.
 - c. GREENGUARD Children and Schools Certified.
- 5. GREENGUARD Certification Program.
 - a. GREENGUARD Indoor Air Quality Certified.
 - b. GREENGUARD Children and Schools Certified.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Delivery:
 - 1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage:
 - 1. Store doors in accordance with manufacturer's instructions.
 - 2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
 - 3. Store doors flat on level surface.
 - 4. Do not store doors directly on concrete.
 - 5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
 - 6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 25 to 55 percent relative humidity.
- C. Handling:
 - 1. Handle doors in accordance with manufacturer's instructions.
 - 2. Protect doors and finish during handling and installation to prevent damage.
 - 3. Handle doors with clean hands or clean gloves.
 - 4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 ENVIRONMENTAL REQUIREMENTS

- A. Do not subject doors to extreme conditions or changes in temperature or relative humidity in accordance with WDMA I.S.1-A.

1.8 WARRANTY

- A. Warrant solid core, interior doors for life of installation against warpage, delamination, and defects in materials and workmanship.

- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehangng as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 1000 Industrial Park, PO Box 490, Holstein, Iowa 51025. Toll Free (800) 827-1615. Phone (712) 368-4381. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 GENERAL

- A. High-Pressure Decorative Laminates: NEMA LD3.
 - 1. Face laminate doors with high-pressure decorative laminates.
 - 2. Nominal Minimum Thickness for Faces and Vertical Edges: 0.048 inch.
 - 3. Laminate Selection: Standard products of Formica, Nevamar, Pionite, Wilsonart, or equal.
 - 4. Finish: Manufacturer's standard.
 - 5. Grade: General purpose, horizontal grade.

Specifier Notes: Delete vision panels if not required.

- B. Vision Panels:
 - 1. VT Industries steel vision frame.
 - 2. Style: No. 110.
 - 3. Finish: Beige finish.
- C. Glazing: As specified in Section 08800 (08 80 00).
- D. Door Louvers: As specified in Section 10225 (08 91 26).

2.3 FLUSH SOLID-CORE HIGH-PRESSURE DECORATIVE LAMINATE DOORS

- A. Flush Solid-Core High-Pressure Decorative Laminate Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

- 1. Model:
 - a. [303H, PC-HPDL-3, PC-20-HPDL-3, PC-20PP-HPDL-3, particleboard core, non-rated or 20-minute rated (3-ply), positive pressure.]
 - b. [3P03H, PC-20PP-HPDL-5, particleboard core, 20-minute rated, positive pressure.]
 - c. [404H, PC-HPDL-5, PC-20-HPLD-5, PC-20PP-HPDL-5, particleboard core, non-rated or 20-minute rated, positive pressure.]
 - d. [4P04H, PC-20PP-HPDL-5, particleboard core, 20-minute rated, positive pressure.]
 - e. [707H, SLC-HPDL-5, SLC-20-HPDL-5, SCL-20PP-HPDL-5, stave lumber core, non-rated or 20-minute rated, positive pressure.]
 - f. [7P07H, SLC-20PP-HPDL-5, stave lumber core, 20-minute rated, positive pressure.]
 - g. [808H, SCLC-HPDL-5, SCLC-20-HPDL-5, SCLC-20PP-HPDL-5, structural composite lumber (SCL), non-rated or 20-minute rated, positive pressure.]
 - h. [8P08H, SCLC-20PP-HPDL-5, structural composite lumber (SCL), 20-minute rated, positive pressure.]

- i. [909H, WSPC-HPDL-5, WSPC-20-HPDL-5, WSPC-20PP-HPDL-5, agrifiber core, non-rated or 20-minute rated, positive pressure.]
- j. [9P09H, WSPC-20PP-HPDL-5, agrifiber core, 20-minute rated, positive pressure.]
- 2. Compliance: WDMA I.S.1-A.
 - a. Aesthetic Grade: Premium.
 - b. Duty Level: Extra heavy duty.
 - c. Type: PC-HPDL-5 or PC-HPDL-3.
- 3. Seven-Ply and Non-Bonded Core Construction: Not acceptable.
- 4. Door Thickness: 1-3/4 inches.
- 5. STC Rating:
 - a. 303H/3P03/404H/4P04H: STC 31, STC 32 with lite 100 to 256 square inches.
 - b. 909H/9P09H: STC 30, non-rated and 20-minute rated.
 - c. 808H/8P08H: STC 33.
 - d. 707H/7P07H: STC 32.
- 6. Stiles:
 - a. 1-3/8 inches wide, before prefitting.
 - b. Structural composite lumber (SCL).
 - c. Edged with high-pressure decorative laminate before face laminates.

Specifier Notes: Edit or delete the following sentence as required. Painting or staining of stile edges is optional.

- d. [Paint] [Stain] stile edges.
- 7. Rails:
 - a. Structural composite lumber (SCL).
 - b. Minimum Width Before Prefitting: 1-3/8 inches.
- 8. Core:

Specifier Notes: Specify the core material.

- a. Material: [Particleboard] [Agrifiber] [Structural composite lumber (SCL)] [Stave lumber].
- b. Particleboard and Agrifiber Compliance: ANSI A208.1, Grade 1-LD-2.
- c. Stave Lumber Core Compliance: Blocks and strips not more than 2-1/2 inches wide, one species of wood.
- d. Structural Composite Lumber Core Compliance: WDMA I.S. 10.

Specifier Notes: Composite crossband is optional. Delete if not required.

- e. Composite Crossband:
 - 1) Apply to core in hot press using Type I, exterior, water-resistant adhesive before application of hardwood edges.
 - 2) Exposed Crossbanding: Not allowed along stile edges.
- 9. Door Assembly:
 - a. Stiles and rails bonded to core.
 - b. Monolithically sand core assembly to ensure minimum telegraphing of core components.
- 10. Laminates:
 - a. Apply to core in hot press using Type I, exterior, water-resistant adhesive.

Specifier Notes: Five-ply construction is standard. Three-ply construction is available for particleboard.

- b. [5-ply] [3-ply] construction.
- 11. Positive Pressure:

- a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
- b. Smoke Gasketing: Apply smoke gasketing around frame perimeter and between door and pairs to meet Smoke (S) rating.
- c. Intertek/Warnock Hersey Category A Guidelines: Edge sealing systems not allowed on frames.

2.4 FLUSH FIRE-RATED HIGH-PRESSURE DECORATIVE LAMINATE DOORS

- A. Flush Fire-Rated High-Pressure Decorative Laminate Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

- 1. Model:
 - a. [1345H, mineral core, FD-45-HPDL-5, 45-minute rated.]
 - b. [1P45H, mineral core, FD-45PP-HPDL-5, 45-minute rated, positive pressure.]
 - c. [1111H, mineral core, FD-60-HPDL-5 and FD-90-HPDL-5, 60- and 90-minute rated.]
 - d. [1P11H, mineral core, FD-60PP-HPDL-5 and FD-90PP-HPDL-5, 60- and 90-minute rated, positive pressure.]
 - e. [9P09H, agrifiber core, FD-45PP-HPDL-5 and FD-60PP-HPDL-60, 45- and 60-minute rated, positive pressure.]
 - f. [8P08H, FD-45PP-HPDL-5 and FD-60PP-HPDL-5, 45-minute rated, positive pressure.]
- 2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
 - b. Duty Level: Extra heavy duty.
 - c. Type: FD-HPDL-5.
- 3. Door Thickness: 1-3/4 inches.
- 4. STC Rating:
 - a. Mineral/Structural Composite Lumber Core: STC 33.
 - b. Agrifiber Core: STC 30.

Specifier Notes: Specify required stiles.

- 5. Stiles: [Structural composite lumber (SCL) with high-pressure decorative laminate edges, 45-minute rated] [Noncombustible material, 60- and 90-minute rated].

Specifier Notes: Specify required rails.

- 6. Rails:
 - a. [Structural composite lumber (SCL), 45-minute rated] [Fire-retardant material, 60- and 90-minute rated].
 - b. Width: Manufacturer's standard width before prefitting.
- 7. Core:
 - a. Fire-Retardant Mineral Core: Does not contain asbestos or added urea formaldehyde.
 - b. Agrifiber Core Door: ANSI A208.1, Grade 1-LD-2.
 - c. Structural Composite Lumber Core: WDMA I.S. 10.
- 8. Composite Crossbands:
 - a. Apply to core in hot press using Type I, exterior, water-resistant adhesive before application of hardwood edges.
 - b. Exposed Crossbanding: Not allowed along stile edges.

9. Positive Pressure:
 - a. Where UBC 7-2-1997/UL 10C standards for positive pressure apply, doors shall be constructed in accordance with Category A guidelines as published by Intertek/Warnock Hersey.
 - b. Smoke Gasketing: Apply smoke gasketing around frame perimeter and between door and pairs to meet Smoke (S) rating.
 - c. Intertek/Warnock Hersey Category B Guidelines: Edge sealing systems not allowed on frames.

2.5 LEAD-LINED DOORS

- A. Lead-Lined Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [1515H, particleboard core, LL-HPDL-7, non-rated.]
 - b. [1P15H, particleboard core, LL-20PP-HPDL-7, 20-minute rated, positive pressure.]
2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
 - b. Duty Level: Extra heavy duty.
3. Non-Rated and 20-Minute-Rated Fire Doors With Lead Sheet on Both Sides of Core:
 - a. Door Thickness: 1-3/4 inches.
 - b. Maximum Combined Lead Thickness: 1/4 inch.
4. Core:
 - a. Particleboard.
 - b. Particleboard Grade: ANSI A208.1, Grade 1-LD-2, for lead-each-side construction.
5. Composite Crossbands:
 - a. Apply to core before application of high-pressure decorative laminate edges.
 - b. Exposed Crossbanding: Not allowed along stile edges.
6. Stiles:
 - a. 1-3/8 inches wide, before prefitting.
 - b. Structural composite lumber (SCL).
 - c. Edged with high-pressure decorative laminate before face laminates for lead-each-side construction.
7. Rails:
 - a. Structural composite lumber (SCL).
 - b. Width: 3-3/8 inches, before prefitting for lead-each-side construction.
8. Lead-Lined Steel Lite Frames on 20-Minute Doors:
 - a. Maximum Lite Opening Size: 256 square inches.
 - b. Maximum Width and Height: 16 inches.
9. Lead Lining:

Specifier Notes: Edit the following sentence if a shielding study is not provided by the Owner.

- a. Thickness and Quality: Conform to shielding study provided by Owner.
- b. Maintain integrity of lead lining.

2.6 SOUND-RETARDANT DOORS

- A. Sound-Retardant Doors: Heritage Collection.

Specifier Notes: Specify the Heritage Collection door model. Consult VT Industries for assistance in choosing the door model for the specific application.

1. Model:
 - a. [1240H, composite sound core, SR-HPDL-5, stained stiles.]
 - b. [1P40H, composite sound core, SR-20PP-HPDL-5, painted stiles, positive pressure.]
 - c. [1250H, sound attenuation core, SR-HPDL-5, stained stiles.]
 - d. [1P50H, sound attenuation core, SR-20PP-HPDL-5, painted stiles, positive pressure.]
2. Compliance: WDMA I.S.1-A.
 - a. Quality Grade: Premium.
3. Testing Methods: ASTM E 90 and E 413.
4. Door Thickness: 1-3/4 inches.

Specifier Notes: Specify STC rating.

5. STC Rating: [39] [45] [48] [49] [50] [51] [52].
6. Core: Sound absorbent material encapsulated by stiles, rails, crossbands, and face laminates.
7. Perimeter Gasketing and Drop Seals: To achieve STC ratings.
8. STC Frames: Required for STC 48 and above.
9. High-Pressure Decorative Laminate Faces: Identical with non-rated and fire-rated doors.
10. Vertical Stile Edges: Painted or matched.

Specifier Notes: Delete the acoustical lite kit if a lite is not required in the door. Using the Model 105 acoustical lite kit, STC 39 doors can maintain the full acoustical rating. The maximum lite size to meet these requirements is 216 square inches or a maximum of 6 inches wide by 36 inches long.

11. Acoustical Lite Kit: Model 105.

2.7 FABRICATION

- A. Stile Edges: Apply laminate edges before application of face laminates.
- B. Prefit Doors:
 1. Prefit and bevel doors at factory to fit openings.
 2. Prefit Tolerances: WDMA I.S.1-A.
- C. Factory-machine doors for mortised hardware, including pilot holes for hinge screws and lock fronts required.
- D. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.
- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust hardware to operate properly.
- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

- A. Protect installed doors from damage during construction.

END OF SECTION

R5/10

VT Industries, Inc.
890 Central Court
New Albany, Indiana 47150
Toll Free (800) 626-6271
Fax (712) 368-4111
Website www.vtindustries.com
E-mail door_info@vtindustries.com

May 2010

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all “Specifier Notes” when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08216 (08 14 33)

STILE AND RAIL WOOD DOORS

Specifier Notes: This section covers VT Industries Artistry Collection architectural interior stile and rail wood doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Architectural interior stile and rail wood doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.

- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.
- D. Section 08800 (08 80 00) – Glazing.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. AWI/AWMAC/WI Architectural Woodwork Standards, Section 9 – Doors.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data.

Specifier Notes: Edit the following sentence as required.

- C. Shop Drawings: Submit manufacturer's shop drawings, including elevations, sections, and details, indicating door construction, dimensions, tolerances, materials, [panels,] [hardware,] [glass] [louvers,] and finish.
- D. Samples:
 - 1. Doors: Submit manufacturer's sample of doors showing materials and finish.

Specifier Notes: Edit the following sentence as required.

- 2. Color: Submit manufacturer's door finish samples, showing range of color variation.
- E. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.
- F. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- G. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Identifying Label: Each door shall bear identifying label indicating:
 - 1. Door manufacturer.
 - 2. Order number.
 - 3. Door number.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
 - 1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage:
 - 1. Store doors in accordance with manufacturer's instructions.
 - 2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
 - 3. Store doors flat on level surface.
 - 4. Do not store doors directly on concrete.
 - 5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
 - 6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 25 to 55 percent relative humidity.
 - 7. Do not subject doors to sudden changes in temperature or relative humidity.
- C. Handling:
 - 1. Handle doors in accordance with manufacturer's instructions.
 - 2. Protect doors and finish during handling and installation to prevent damage.
 - 3. Handle doors with clean hands or clean gloves.
 - 4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 WARRANTY

- A. Warrant interior doors for 5 years in interior use against warpage, delamination, and defects in materials and workmanship.
- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehanging as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 890 Central Court, New Albany, Indiana 47150. Toll Free (800) 626-6271. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 STILE AND RAIL WOOD DOORS

- A. Architectural Interior Stile and Rail Wood Doors: Artistry Collection.

Specifier Notes: Specify Artistry Collection door series and models. Consult VT Industries for Artistry Collection custom stile and rail doors.

- 1. 1000 Series, Wood Panels: Model [1011A] [1021A] [1031A] [1032A] [1041A] [1042A] [1051A] [1052A] [1061A] [1062A] [1063A] [1081A] [1091A].

2. 3000 Series, Glass Panels: Model [3011A] [3021A] [3022A] [3024A] [3032A] [3041A] [3042A] [3052A] [3061A] [3062A] [3063A] [3081A] [3091A] [3101A] [3121A] [3151A] [3181A].
3. 5000 Series, Wood and Glass Panels: Model [5021A] [5031A] [5071A] [5101A] [5111A] [5131A] [5141A].
4. 7000 Series, Louver Panels: Model [7011A] [7021A].
5. 9000 Series, Wood and Louver Panels: Model [9021A] [9022A].
6. Custom elevations.

Specifier Notes: Specify premium grade construction. Premium grade is standard.

B. Compliance: AWS, Section 9, premium grade.

C. Design:

Specifier Notes: Specify panel type.

1. Panel Type: [Flat] [Raised] [Glass] [Louver].
2. Door Top: Square.
3. Top Panel: Square.

D. Non-Rated Doors: Artistry Collection.

Specifier Notes: Specify dimensions for Artistry Collection non-rated doors. Refer to manufacturer's product listing for approved component dimensions.

1. Door Thickness: [1-3/4 inches] [_____ inches].
2. Stile Width: 6 inches, unless otherwise noted.
3. Mullion Width: 3 inches, unless otherwise noted.
4. Rails:
 - a. Top Rail Width: 6 inches, unless otherwise noted.
 - b. Lock Rail Width: 8-3/4 inches, unless otherwise noted.
 - c. Cross Rail Width: 3 inches, unless otherwise noted.
 - d. Bottom Rail Width: 10 inches, unless otherwise noted.
5. Panels:

Specifier Notes: Specify thickness for flat or raised panels.

- a. Flat Panel Thickness: [1/2 inch] [_____ inch].
- b. Raised Panel Thickness: [1-1/4 inches] [_____ inches].

Specifier Notes: Delete glass if not specified. Doors may be factory glazed or field glazed as determined by the Contractor.

6. Glass:
 - a. Type: _____ .

- b. Thickness: _____ .

Specifier Notes: Specify type of louvers. Delete louvers if not specified.

7. Louvers: [Chevron] [Flat slat] [_____].

Specifier Notes: Specify bar/muntin width and thickness for 3000 and 5000 Series doors only.

8. Bar/Muntin:
a. Width: 1/2 inch.
b. Thickness: 1-3/4 inches.

2.3 DOOR CONSTRUCTION

- A. Stile Edge: Matching hardwood stile edge.
- B. Inner Stile and Rail:
1. Non-Rated Doors and 20-Minute Fire-Rated Doors: Specified wood veneer pressed over structural composite lumber.
- C. Panels:
1. Mitered rim banded panels.
2. Center balanced, book match.
- D. Stile and Rail Joints: Doweled construction.
- E. Hinges and Face Plates: Factory drill pilot holes.

Specifier Notes: Specify sticking used with panels, louvers, or glass.

- F. Sticking Used with [Panels] [Louvers] or [Glass]: [Ovolo] [Square] [Ogee].

2.4 HARDWARE

- A. Factory machine doors in accordance with templates from specified hardware manufacturers and hardware schedule.

2.5 FINISH

- A. Stile and Rail Doors: Manufacturer's factory finish.
- B. Factory Finish: VT Industries factory finish.
1. Description: AWS System 2, precatalyzed lacquer.

Specifier Notes: Omit the stain coat if a clear finish is desired.

- a. Stain coat.
- b. Sealer coat.
- c. Sanding: Sand.
- d. Topcoat: 2 coats.

Specifier Notes: Specify the stain color. Consult VT Industries for custom stain and paint colors and for minimum size of physical sample required for custom color matching.

- C. Stain Color: [Clear] [Alpine] [Grassland] [Oasis] [Ravine] [Savanna] [Timber] [Wheat] [_____].
- D. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.
- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust hardware to operate properly.

- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

- A. Protect installed doors from damage during construction.

END OF SECTION

VT Industries, Inc.
1000 Industrial Park
PO Box 490
Holstein, Iowa 51025
Toll Free (800) 827-1615
Phone (712) 368-4381
Fax (712) 368-4111
Website www.vtindustries.com
E-mail door_info@vtindustries.com

May 2010

Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The Project Resource Manual—CSI Manual of Practice*.

The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all “Specifier Notes” when editing this section.

Section numbers are from *MasterFormat* 1995 Edition, with numbers from *MasterFormat* 2004 Edition in parentheses. Delete version not required.

SECTION 08216 (08 14 33)

STILE AND RAIL WOOD DOORS

Specifier Notes: This section covers VT Industries Heritage Collection architectural interior stile and rail wood doors. Consult VT Industries for assistance in editing this section for the specific application. Visit www.vtindustries.com/doors/awdSalesReps.aspx to locate a Territory Sales Manager in your region.

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Architectural interior stile and rail wood doors.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

- A. Section 06460 (06 48 00) – Wood Frames.
- B. Section 08100 (08 12 00) – Metal Frames.
- C. Section 08710 (08 71 00) – Door Hardware.
- D. Section 08800 (08 80 00) – Glazing.

1.3 REFERENCES

Specifier Notes: List standards referenced in this section, complete with designations and titles. Delete standards not used in this section. This article does not require compliance with standards, but is merely a listing of those used.

- A. NFPA 80 – Standard for Fire Doors and Other Opening Protectives.
- B. Window and Door Manufacturers Association:
 - 1. ANSI/WDMA I.S.6-A – Industry Standards for Architectural Wood Stile & Rail Doors.
 - 2. WDMA TR-6 – Factory Finish Catalyzed Polyurethane.

1.4 SUBMITTALS

- A. Comply with Section 01330 (01 33 00) – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data.

Specifier Notes: Edit the following sentence as required.

- C. Shop Drawings: Submit manufacturer's shop drawings, including elevations, sections, and details, indicating door construction, dimensions, tolerances, materials, [panels,] [hardware,] [glass,] [louvers,] and finish.
- D. Samples:
 - 1. Doors: Submit manufacturer's sample of doors showing materials and finish.
 - 2. Color: Submit manufacturer's door finish samples, showing range of color variation.
- E. Manufacturer's Certification: Submit manufacturer's certification that doors comply with specified requirements and are suitable for intended application.
- F. Cleaning Instructions: Submit manufacturer's cleaning instructions for doors.
- G. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Identifying Label: Each door shall bear identifying label indicating:
 - 1. Door manufacturer.
 - 2. Order number.
 - 3. Door number.
 - 4. Fire rating, if applicable.

Specifier Notes: Delete the following paragraph if fire-rated doors are not required.

- B. Fire-Rated Doors: Labeled by Intertek/Warnock Hersey.
 - 1. Construction Details and Hardware Application: Approved by labeling agency.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
 - 1. Deliver doors to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage:
 - 1. Store doors in accordance with manufacturer's instructions.
 - 2. Store doors in clean, dry area indoors, protected from damage and direct sunlight.
 - 3. Store doors flat on level surface.
 - 4. Do not store doors directly on concrete.
 - 5. Keep doors completely covered. Use covering which allows air circulation and does not permit light to penetrate.
 - 6. Store doors between 50 and 90 degrees F (10 and 32 degrees C) and 25 to 55 percent relative humidity.
 - 7. Do not subject doors to sudden changes in temperature or relative humidity.
- C. Handling:
 - 1. Handle doors in accordance with manufacturer's instructions.
 - 2. Protect doors and finish during handling and installation to prevent damage.
 - 3. Handle doors with clean hands or clean gloves.
 - 4. Lift and carry doors. Do not drag doors across other doors or surfaces.

1.7 WARRANTY

- A. Warrant interior doors for 5 years in interior use against warpage, delamination, and defects in materials and workmanship.
- B. Defects noted during warranty period shall be corrected at no cost to Owner. Corrective work shall include labor and material for repair, replacement, refinishing, and rehanging as required.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. VT Industries, Inc., 1000 Industrial Park, PO Box 490, Holstein, Iowa 51025. Toll Free (800) 827-1615. Phone (712) 368-4381. Fax (712) 368-4111. www.vtindustries.com. door_info@vtindustries.com.

2.2 STILE AND RAIL WOOD DOORS

- A. Architectural Interior Stile and Rail Wood Doors: Heritage Collection.

Specifier Notes: Specify Heritage Collection door series and models. Consult VT Industries for Heritage Collection custom stile and rail doors.

1. 1000 Series, Wood Panels: Model [1011H] [1021H] [1031H] [1032H] [1041H] [1042H] [1051H] [1052H] [1061H] [1062H] [1063H] [1081H] [1091H].
2. 3000 Series, Glass Panels: Model [3011H] [3021H] [3022H] [3024H] [3032H] [3041H] [3042H] [3052H] [3061H] [3062H] [3063H] [3081H] [3091H] [3101H] [3121H] [3151H] [3181H].
3. 5000 Series, Wood and Glass Panels: Model [5021H] [5031H] [5041H] [5071H] [5101H] [5111H] [5131H] [5141H].
4. 7000 Series, Louver Panels: Model [7011H] [7021H].
5. 9000 Series, Wood and Louver Panels: Model [9021H] [9022H].
6. Custom elevations.

Specifier Notes: Specify custom grade construction. Custom grade is standard.

- B. Compliance: WDMA I.S.6-A, custom grade.
- C. Design:

Specifier Notes: Specify panel type.

1. Panel Type: [Flat] [Raised] [Glass] [Louver].

Specifier Notes: Specify door top.

2. Door Top: [Square] [Arch] [Radius].

Specifier Notes: Specify top panel.

3. Top Panel: [Square] [Arch] [Colonial] [Radius].

- D. Non-Rated Doors and 20-Minute Fire Doors: Heritage Collection.

Specifier Notes: Specify dimensions for Heritage Collection non-rated doors and 20-minute fire doors. Refer to manufacturer's product listing for approved component dimensions.

1. Door Thickness: 1-3/4 inches.
2. Stile Width: 6 inches, unless otherwise noted.
3. Mullion Width: 3 inches, unless otherwise noted.
4. Rails:
 - a. Top Rail Width: 6 inches, unless otherwise noted.
 - b. Lock Rail Width: 8-3/4 inches, unless otherwise noted.
 - c. Cross Rail Width: 3 inches, unless otherwise noted.
 - d. Bottom Rail Width: 10 inches, unless otherwise noted.
5. Panels:

Specifier Notes: Specify thickness for flat or raised panels.

- a. Flat Panel Thickness: 5/8 inch.
- b. Raised Panel Thickness: 1-1/8 inches.

Specifier Notes: Delete glass if not specified. Doors may be factory glazed or field glazed as determined by the Contractor.

6. Glass:
 - a. Type: _____ .
 - b. Thickness: _____ .

Specifier Notes: Specify type of louvers. Delete louvers if not specified.

7. Louvers: [Chevron] [Flat slat] [_____].

Specifier Notes: Specify bar/muntin width and thickness for 3000 and 5000 Series doors only.

8. Bar/Muntin:
 - a. Width: 1/2 inch.
 - b. Thickness: 1-3/4 inches.
9. Veneers:

Specifier Notes: Specify the face veneer species and cut.

- a. Species: _____ .
- b. Cut: [Rotary] [Plain sliced] [Quarter] [_____].

F. 45-, 60-, and 90-Minute Fire-Rated Doors: Heritage Collection.

Specifier Notes: Specify dimensions for Heritage Collection 45-, 60-, and 90-minute fire-rated doors. Refer to manufacturer's product listing for approved component dimensions.

1. Door Thickness: 1-3/4 inches.
2. Stile Width: 6 inches.

3. Mullion Width: 3 inches.
4. Rails:
 - a. Top Rail Width: 6 inches.
 - b. Lock Rail Width: 8-3/4 inches.
 - c. Cross Rail Width: 3 inches.
 - d. Bottom Rail Width: 10 inches.
5. Panels:

Specifier Notes: Specify thickness for flat or raised panels.

- a. Flat Panel Thickness: 7/8 inch.
 - b. Raised Panel Thickness: 1-11/32 inches.
 - c. Minimum Panel Size: 11-1/2 inches by 11-1/2 inches.
6. Fire Labels: Attach permanent fire label on hinge stile of each fire-rated door.

2.3 DOOR CONSTRUCTION

- A. Stile Edge: Matching hardwood stile edge.
- B. Inner Stile and Rail:
 1. Non-Rated Doors and 20-Minute Fire-Rated Doors: Specified wood veneer pressed over structural composite lumber.
 2. 45-, 60-, and 90-Minute Fire-Rated Doors: Specified wood veneer pressed over noncombustible material.
- C. Panels:
 1. Specified wood veneer pressed over medium-density fiber core.
 2. Specified wood veneer pressed over fire-retardant core.
- D. Stile and Rail Joints: Doweled construction.
- E. Hinges and Face Plates: Factory drill pilot holes.

Specifier Notes: Specify sticking used with panels, louvers, or glass.

- F. Sticking Used with [Panels] [Louvers] or [Glass]: [Ovolo] [Square] [Ogee].

2.4 HARDWARE

- A. Factory machine doors in accordance with templates from specified hardware manufacturers and hardware schedule.

2.5 FINISH

- A. Stile and Rail Doors: Manufacturer's factory finish.
- B. Factory Finish: VT Industries factory finish.
 1. Description: WDMA TR-6 catalyzed polyurethane system.

Specifier Notes: Specify stain color, unless clear finish is required. Consult VT Industries for availability of custom stain colors. A minimum 3-inch by 5-inch physical sample is required for custom color matching.

- a. Clear Finish: Clear.
 - b. Stain Color: [Alpine] [Grassland] [Oasis] [Ravine] [Savanna] [Timber] [Wheat].
 - c. Prime for opaque finished doors.
2. Sealers and Topcoats: UV-cured polyurethane.
- C. Top and Bottom Rails: Factory sealed.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine locations to receive doors. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.
- B. Ensure frames are solidly anchored, allowing no deflection when doors are installed.
- C. Ensure frames are plumb, level, square, and within tolerance.

3.2 PREPARATION

- A. Allow doors to become acclimated to building temperature and relative humidity for a minimum of 24 hours before installation.

3.3 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions.

Specifier Notes: Edit the following sentence as required.

- B. Install doors at locations indicated on the [Door Schedule] [Drawings].
- C. Install doors plumb, level, and square.
- D. Install door hardware as specified in Section 08710 (08 71 00).

3.4 ADJUSTING

- A. Adjust doors to swing freely, without binding in frame.
- B. Adjust hardware to operate properly.

- C. Repair minor damages to finish in accordance with manufacturer's instructions and as approved by Architect.
- D. Remove and replace damaged doors that cannot be successfully repaired, as determined by Architect.

3.5 CLEANING

- A. Clean doors promptly after installation in accordance with manufacturer's instructions.
- B. Do not use harsh cleaning materials or methods that could damage finish.

3.6 PROTECTION

- A. Protect installed doors from damage during construction.

END OF SECTION