



LEAD LINED DOOR NOTES

1. The maximum lite size allowed on 20-minute lead lined doors is 256 square inches (maximum 16" wide x 16" high).
2. Lead lined doors require lead lined vision panels. (Wood stops are not allowed).
3. The maximum fire rating for a lead lined door is 20-minute.
4. Maximum door size for single doors is 4-0 x 8-0 and for pairs is 8-0 x 8-0.
5. Lead lined doors have a sheet of lead on either side of the core.

| | | | | | |
|------------|-------|---|-------|----|---------|
| 2 sheets @ | 1/32" | = | 1/16" | or | 4 lbs. |
| 2 sheets @ | 1/16" | = | 1/8" | or | 8 lbs. |
| 2 sheets @ | 1/8" | = | 1/4" | or | 16 lbs. |
6. Lead lined pairs of doors must always have a lead lined astragal. (Wood not allowed).
7. A lead lined door cannot be made with stave lumber core.