SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

## **Eggers Division LLC of VT Industries, Inc.**

One Eggers Drive, Two Rivers, WI, United States

For the following product(s):

Wallcoverings: Architectural Plywood

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## Indoor Advantage<sup>™</sup> Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0 Conforms to CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January 2017) for the school classroom<sup>1</sup>, private office<sup>1</sup>, and single-family residence<sup>1</sup> parameters. <sup>1</sup> Modeled Product Type: Wallcovering

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m 3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-04566 Valid from: August 1, 2021 to July 31, 2022





Hanley Mathie

Stanley Mathuram, PE, Vice President SCS Global Services 2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

