



# Product Update

APR 04, 2002

#P135F

Revision 00

---

Applies to Flush doors

## **RACEWAY LOCATION APPROVAL IN 20-MINUTE THROUGH 90-MINUTE POSITIVE PRESSURE FIRE DOORS ABOVE THE 40" NEUTRAL PLANE**

Based on the EPT device approval in 20-minute through 90-minute positive pressure fire doors as outlined in Product Update #P134F, other electrified hardware items that require a raceway, such as electric hinges and locks, are also allowed to be located above the 40" neutral plane.