



Product Update

December 13, 2016

#P161FSR

Revision 01

Applies to Flush

ELIMINATION OF INTUMESCENT IN 20-MINUTE SINGLE SWING POSITIVE PRESSURE FIRE DOORS

Based on an Engineering Evaluation (EEV) by Intertek/Warnock Hersey, single swing 20-minute positive pressure fire rated doors installed into hollow metal frames no longer require intumescent incorporated into the door.

The maximum size for flush doors is 4-0 x 9-0 (single opening- larger sizes up to 4-0 x 10-0 and doors in pairs require intumescent).

Note: Doors going into frames in a drywall system require listed smoke and draft control gasketing.